

Critical Contingency Termination Notice

Date:	23 May 2017
Time:	18:20
Notice Number:	CC-0041
Notice Type:	Critical Contingency Termination
Notice Issued To:	First Gas TSO Stakeholders listed in Information Guide Interested Parties
CCO Instruction to TSO:	The Critical Contingency has been terminated. Issue notice of Termination of Critical Contingency to Large Consumers and Retailers within 30 minutes and ensure an appropriate critical notice is posted on OATIS and direct retailers to advise their consumers that the critical contingency has been terminated.
Critical Contingency Termination Time & Date:	18:15 on 23 May 2017
Current Status:	The CCO has determined that the Critical Contingency situation has been resolved. The supply of gas into the system is currently sufficient to meet or exceed the reasonably expected demand.
Event that caused Critical Contingency:	During a planned outage of the Pohokura Production Station, pipeline linepack and pressures on the Transmission System dropped to the point where the Critical Contingency pressure threshold at Kapuni Gas Treatment Plant was breached. The CCO was required to declare a Critical Contingency because of the pressure threshold breach.
Details of Event resolution:	Pohokura Production Station returned to anticipated flows and Transmission System pressures are above the Critical Contingency thresholds.
CCO determination on Regional Critical Contingency Status:	Non-Regional.
Areas of transmission system affected:	All areas.

This notice is issued pursuant to **Regulation 60** of the Gas Governance (Critical Contingency Management) Regulations 2008 and amendments. All directions issued by the CCO pursuant to this declaration must be complied with.

This notice is issued in accordance with the General Critical Contingency Notice Conditions contained in the CCO Information Guide, CCO Communications Plan and First Gas CCMP's.

The CCO will issue advice of this Notice of Critical Contingency Termination to the stakeholders listed in the CCO Information Guide and publish this notice in the public domain of the CCO web site at <http://www.cco.org.nz>