

Critical Contingency Termination Notice

Date:	26 September 2024
Time:	02:45am
Notice Number:	CC-088
Notice Type:	Critical Contingency Termination
Notice Issued to:	Firstgas TSO Stakeholders listed in the CCO Information Guide
CCO Instruction to TSO:	The Critical Contingency has been terminated. Issue notice of Termination of Critical Contingency to Large Consumers and Retailers within 30 minutes and ensure an appropriate critical notice is posted on OATIS and direct retailers to advise their consumers that the critical contingency has been terminated.
Critical Contingency Termination Time & Date:	26 September 2024 02:30am
Current Status:	The transmission system is stable. The gas supply into the Mount Maunganui gas gate has been restored.
Event that caused Critical Contingency:	The gas supply to the Mount Maunganui gas gate became blocked causing a breach of the critical contingency pressure threshold.
Details of Event resolution:	Firstgas has cleared the blockage and supply has been restored.
Regional Critical Contingency Status:	Regional
Transmission pipeline(s) affected:	The Firstgas Bay of Plenty Pipeline
Geographic area affected:	Mount Maunganui

This notice is issued pursuant to **Regulation 60** of the Gas Governance (Critical Contingency Management) Regulations 2008 and amendments. All directions issued by the CCO pursuant to this declaration must be complied with.

This notice is issued in accordance with the General Critical Contingency Notice Conditions contained in the CCO Information Guide, CCO Communications Plan and First Gas CCMP.

The CCO will issue advice of this Notice of Critical Contingency Termination to the stakeholders listed in the CCO Information Guide and publish this notice in the public domain of the CCO web site at <https://www.cco.org.nz/current-event/>